



Also Doing Business As (DBA):



Kenneth D. Ellsworth, P.E.
Managing Member

Paul L. Bedford, AIA
Architect

Rodney L. Carey, L.S.
Land Surveyor

Kordian W. Wichtowski, R.A.
Architect

June 26, 2015

William H. Illing, P.E.
Superintendent of Public Works
Town of Fallsburg
5410 State Rte. 42
PO Box 830
South Fallsburg, New York 12779

RE: Site Inspections
Evergreen Condominiums
SBL No. 11-1-11.2 and 11.8-1-26.1
11B-1-26.4 and 11-1-11.4

Dear Mr. Illing:

We have completed our review of the water and sewer test reports for the above referenced project and find them acceptable with the following comments.

While reviewing the drawings and report, we noticed some changes that were made during construction. We are expecting that the as-built drawings will reflect these changes.

Manholes 31-A4 and 31-5 were not tested. We are assuming these will be tested during Phase 2 of the project.

If you have any questions, please do not hesitate to contact our office.

Very truly yours,

Keystone Associates
Architects, Engineers & Surveyors, LLC

Kenneth D. Ellsworth, P.E.
Managing Member

KDE:mlw

CC: Mollie Messenger
Paige Bakken

P:\Projects\2012\1383\1383_02112\1383_02112_2_EvergreenCondos\Correspondence\15_0626WILtr.docx