



Also Doing Business As (DBA):



Kenneth D. Ellsworth, P.E.
Managing Member

Paul L. Bedford, AIA
Architect

Rodney L. Carey, L.S.
Land Surveyor

Kordian W. Wichtowski, R.A.
Architect

August 29, 2017

Mr. William H. Illing, P.E.
Superintendent of Public Works
Town of Fallsburg
5410 State Rte. 42
PO Box 830
South Fallsburg, New York 12779

RE: Site Inspection
Maplewood Estates
SBL No. 106-4-13.2 and 109-1-2.1

Dear Mr. Illing:

We performed a site inspection on August 25, 2017 to verify elevations prior to the placement of concrete footers. The table below indicates our results. According to our results they are within an acceptable tolerance to construct the footers.

Point Number	Description	NAVD 88	Elevation with Correction	Design Elevation	Δ
	INVERT		506.17-8.0"D=		
301	(MHA3)	1117.17	505.50	505.50	0.0
302	BLD-33/34	1134.83	523.83	523.70	+0.13
305	BLD-31/32	1139.92	528.92	528.70	+0.22
306	BLD-29/30	1141.88	530.88	530.70	+0.18
307	BLD-25/26	1146.08	535.08	534.70	+0.38
308	BLD-21/22	1146.24	535.24	534.70	+0.54

If you have any questions, please do not hesitate to contact our office.

Very truly yours,

Keystone Associates
Architects, Engineers and Surveyors, LLC

Kenneth D. Ellsworth, P.E.
Managing Member

KDE:las

cc: Mollie Messenger
George Sarvis

58 Exchange Street
Binghamton, New York 13901
Phone: 607.722.1100
Fax: 607.722.2515
E-mail: info@keyscomp.com
www.keyscomp.com