



Also Doing Business As (DBA):



Kenneth D. Ellsworth, P.E.
Managing Member

Paul L. Bedford, AIA
Architect

Rodney L. Carey, L.S.
Land Surveyor

Kordian W. Wichtowski, R.A.
Architect

February 24, 2017

Mr. Leonard Jackson, P.E.
Leonard Jackson Associates
Consulting Engineers
26 Firemens Memorial Drive
Pomona, New York 10970

RE: Orchards
Clearing Plan
SBL No. 12-1-11.1

Dear Mr. Jackson:

We have reviewed the "Clearing Plan" with a latest revision date of February 17, 2017. We concur with Mollie Messenger's email dated February 23, 2017 and have paraphrased her comments below:

1. Tree stump burial Area 1 (0.27 acres) is located within the required 50' setback which is not allowed.
2. Tree stump burial Area 2 (0.42 acres) proposed location is partially within existing woods. We do not recommend removing additional trees for stump burial.
3. Tree stump burial Area 3 (0.31 acres) proposed location is also within existing woods and within the 200 foot protection zone of the well.

Although a portion of Area 2 may be acceptable for stump burial, it is our opinion that the stumps should be ground into chips in accordance with Note No. 4, drawing No. 2 of the approved plans.

If you have any questions, please do not hesitate to contact our office.

Very Truly Yours,

Keystone Associates
Architects, Engineers & Surveyors, LLC

Kenneth D. Ellsworth, P.E.
Managing Member

KDE:las

CC: William Illing, P.E.
Mollie Messenger
Paula Kay, Esq.
Kyle Ellsworth
Mari Giurastante

58 Exchange Street
Binghamton, New York 13901
Phone: 607.722.1100
Fax: 607.722.2515
E-mail: info@keyscomp.com
www.keyscomp.com

P:\Projects\2011\1383\1383_0021\1383_0021_4 - Orchards\Correspondence\17_0224LtrLJ.doc