

Facility Name: THE ORCHARDS

County: SULLIVAN

1

Facility Address: Labaugh ROAD
Fallsburg, NY 12733

Facility Code: 52SUB105

Operation Type: Swimming Pool

Name of Operator: Oco Realty, LLC

Operation Name: THE ORCHARDS-Mens

In accordance with the provisions of Part 6-1.6(b) of the New York State Sanitary Code, the operator of the above named facility is granted a Waiver from compliance with section 6-1.29, Item 9.5.2.

Details of Waiver

Subpart 6-1.29.9.5.2 limits the use of skimmers to swimming pools with a water surface area less than 1600 sq.ft. The proposed swimming pool design specifies a water surface area of 1974 sq.ft with six skimmers provided in lieu of a gutter overflow system and the one skimmer/400 sq.ft requirement.


Condition(s) and/or Reason(s) for Granting this Waiver

1. Three floor inlets proposed across entire pool to promote water circulation
2. Six skimmers proposed to promote water circulation
3. Recirculation system provides for a 4.57 hour turnover of entire pool volume
4. The two recirculation pumps shall not be operated under excessive vacuum
5. Variable-frequency drive controlled pumps automatically maintain flow at the design recirculation rate of 260 gpm

This Waiver is issued on the condition that the facility is maintained and operated in compliance with all other sections of the State Sanitary Code.

Waivers shall remain in effect until revoked by the Permit Issuing Official. This notice shall be posted or kept on file, and made available by the operator on request.

Date Issued: November 04, 2016


Michelle Glover-Brown

Signature of Permit Issuing Official

Title

State of New York Department of Health

MDO, Sector E

Notice of Waiver Granted

Facility Name: THE ORCHARDS

County: SULLIVAN

1

Facility Address: Labaugh ROAD
Fallsburg, NY 12733

Facility Code: 52SUB105

Operation Type: Swimming Pool

Name of Operator: Oco Realty, LLC

Operation Name: THE ORCHARDS-Women

In accordance with the provisions of Part 6-1.6(b) of the New York State Sanitary Code, the operator of the above named facility is granted a Waiver from compliance with section 6-1.29, Item 9.5.2.

Details of Waiver

Subpart 6-1.29.9.5.2 limits the use of skimmers to swimming pools with a water surface area less than 1600 sq. ft. The proposed swimming pool design specifies a water surface area of 1974 sq. ft. with six skimmers provided in lieu of a gutter system and the one skimmer/400 sq. ft. requirement.

Condition(s) and/or Reason(s) for Granting this Waiver

1. Three floor inlets proposed across entire pool to promote water circulation
2. Six skimmers proposed to promote water circulation
3. Recirculation system provides for a 4.57 hour turnover of entire pool volume
4. The two recirculation pumps shall not be operated under excessive vacuum
5. Variable-frequency drive controlled pumps automatically maintain flow at the design recirculation rate of 260 gpm

This Waiver is issued on the condition that the facility is maintained and operated in compliance with all other sections of the State Sanitary Code.

Waivers shall remain in effect until revoked by the Permit Issuing Official. This notice shall be posted or kept on file, and made available by the operator on request.

Date Issued: November 04, 2016


Michelle Glover-Brown
Signature of Permit Issuing Official


Title

State of New York Department of Health

MDO, Sector E