

Orchards Labaugh Road
SBL# 12-1-11-1

Elevation Checks
July 27, 2017

		Top of Stone	Top of Slab	Design Elevation
Foundation Walls	8	1512.84	1513.84	1514.0
	9	1516.69	1517.69	1518.0
	10	1521.77	1522.77	1523.0
	12	1526.77	1527.77	1528.0

Tunnel

1. Interior Joints should be mortared smooth.