

Notice of Waiver Granted

Facility Name: 290 LAUREL AVE, LLC

County: SULLIVAN

Facility Address: 290 Laurel AVENUE

Facility Code: 52-AN332

South Fallsburg, NY 12779

Operation Type: Swimming Pool

Name of Operator: Shulem Kessler

Operation Name: 290 LAUREL AVE, LLC- men's

In accordance with the provisions of Part 6-1.6(b) of the New York State Sanitary Code, the operator of the above named facility is granted a Waiver from compliance with section 6-1.29, Item 7.1.1.

Details of Waiver

Subpart 6-1.29.7.1.1 states overhead illumination on the water surface shall be a minimum of 30 foot-candles when underwater lighting as specified in item 7.1.2 is provided. Section 7.1.2 states, when underwater lighting is used, not less than 0.5 watt per square foot of pool water surface shall be provided.

Plans and specifications for the proposed outdoor pool call for a minimum of 10 foot-candles of light over the water surface and within 5 feet of the pool instead of 30 foot-candles.

The proposed 10 foot-candle deck level lighting is expected to provide clear visibility of all potential hazards on the deck surface, clear visibility of all signage, and clear view of bathers in water.

Condition(s) and/or Reason(s) for Granting this Waiver

1. The proposed underwater lighting in the pool provides a minimum of 0.92 watts per square foot which is 84% greater than the minimum required by Subpart 6-1.29.7.1.2., thereby increasing swimmer visibility below the water surface.
2. For outdoor venues, 10 foot-candles of illumination on the pool water surface and deck area is consistent with the minimum requirement cited in the CDC Model Aquatics Health Code (2nd Ed.)
3. If the Department determines lighting is inadequate to ensure safe operation of the pool, additional lighting will become a requirement and may result in pool closure until the Department determines adequate measures are in place.

This Waiver is issued on the condition that the facility is maintained and operated in compliance with all other sections of the State Sanitary Code.

Waivers shall remain in effect until revoked by the Permit Issuing Official. This notice shall be posted or kept on file, and made available by the operator on request.

Date Issued: December 19, 2017




Kelly VanDerVliet

Signature of Permit Issuing Official

State of New York Department of Health

MDO, Sector A



Title

Notice of Waiver Granted

Facility Name: 290 LAUREL AVE, LLC

County: SULLIVAN

Facility Address: 290 Laurel AVENUE

Facility Code: 52-AN332

South Fallsburg, NY 12779

Operation Type: Swimming Pool

Name of Operator: 290 Laurel Ave, LLC

Operation Name: 290 LAUREL AVE, LLC- womens

In accordance with the provisions of Part 6-1.6(b) of the New York State Sanitary Code, the operator of the above named facility is granted a Waiver from compliance with section 6-1.29, Item 7.1.1.

Details of Waiver

Subpart 6-1.29.7.1.1 states overhead illumination on the water surface shall be a minimum of 30 foot-candles when underwater lighting as specified in item 7.1.2 is provided. Section 7.1.2 states, when underwater lighting is used, not less than 0.5 watt per square foot of pool water surface shall be provided.

Plans and specifications for the proposed outdoor pool call for a minimum of 10 foot-candles of light over the water surface and within 5 feet of the pool instead of 30 foot-candles.

The proposed 10 foot-candle deck level lighting is expected to provide clear visibility of all potential hazards on the deck surface, clear visibility of all signage, and clear view of bathers in water.

Condition(s) and/or Reason(s) for Granting this Waiver

1. The proposed underwater lighting in the pool provides a minimum of 0.92 watts per square foot which is 84% greater than the minimum required by Subpart 6-1.29.7.1.2., thereby increasing swimmer visibility below the water surface.
2. For outdoor venues, 10 foot-candles of illumination on the pool water surface and deck area is consistent with the minimum requirement cited in the CDC Model Aquatics Health Code (2nd Ed.)
3. If the Department determines lighting is inadequate to ensure safe operation of the pool, additional lighting will become a requirement and may result in pool closure until the Department determines adequate measures are in place.

This Waiver is issued on the condition that the facility is maintained and operated in compliance with all other sections of the State Sanitary Code.

Waivers shall remain in effect until revoked by the Permit Issuing Official. This notice shall be posted or kept on file, and made available by the operator on request.

Date Issued: December 19, 2017



Kelly VanDerVliet

Signature of Permit Issuing Official

State of New York Department of Health

MDO, Sector A



Title