

#117-33

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION

DEC 11 2017

Division of Water, Region 3
21 South Platt Corners Road, New Paltz, NY 12561-1620
P: (845) 256-3000 | F: (845) 255-3414
www.dec.ny.gov

December 6, 2017

D. Randel Wasson, P.E.
Wasson Engineering
5 McDonald Road, Suite 2
Wurtsboro, NY 12790

RE: Compliance Schedule Camp Ohr Shalom – CO 3-20170710-131
Camp Ohr Shalom
SPDES: NY0271179
228 Todd Road, Woodbourne, NY 12788
Town of Fallsburg, Sullivan County

Dear Mr. Wasson:

The Department has performed a review of items (i), (ii), and (iii) dated October 27, 2017 associated with the above referenced consent order with the following comments:

- 1) The signed Certification of Compliance (iii) was not included in the packet of documents dated October 27, 2017. Please submit the signed Certification of Compliance.
- 2) The Wastewater Facility Operation Reports for July and August 2017 were reviewed. Five total residual chlorine (TRC) exceedances occurred in July and 3 chlorine residual exceedances occurred in August. Please submit a corrective action plan to address the violation of TRC limit.
- 3) Please add the second set of two 3,000 gallon septic tanks into the upcoming plan submission as originally designed and approved. Outfall 001B has been approved for 8,000 GPD; therefore, primary treatment will need to be sized to handle the total permitted flow.
- 4) Provide an update on future plans for outfalls 001A and 001B. Outfall 001B was proposed as a temporary system/solution prior to construction of 001A. The April 2009 Engineering Report by Lanc & Tully states that the construction of Outfall 001A will be delayed due to current economic conditions. Are there any plans to move forward with Outfall 001A?


Please submit two (2) sets of stamped and signed revised plans and details to this office by January 15, 2018 as stated in the submitted Schedule of Compliance. Construction shall not commence without prior approval of plans by this office.



Department of
Environmental
Conservation

Should you have any questions, please contact me at (845) 256-3019.

Sincerely,

A handwritten signature in cursive script that reads "Sean Howard".

Sean Howard
Assistant Engineer

ecc: Shohreh Karimipour, P.E., RWE, NYSDEC
Adedayo Adewole, P.E., NYSDEC
File