## **TOWN OF FALLSBURG**

## Planning Board Work Session

PBWS MEETING DATE: 12/6/2017 SBL# 12.-1-26 / 30.1 MAP DATE:

PROJECT NAME: HASBROUCK ESTATES

PRESENTORS: K. ROTHER, J. ZEIGER, N. BERNHACK, K. WERSTED

ATTENDANCE: K. ELLSWORTH, W. ILLING, M. GIURASTANTE, A. ROSENSHEIN, M. MESSENGER

PLEASE CHECK ALL THAT APPLY

Concept Plan \_\_\_\_\_ Informal Discussion \_\_\_\_ Subdivision \_\_\_\_ Site Plan \_\_x \_ Amended Site Plan \_\_\_\_\_

Special Permit \_\_\_\_ Preliminary \_\_\_\_ Final \_\_\_\_ ARB\_\_\_\_

Application ready for Board? Yes \_\_\_ X\_\_ No \_\_\_\_\_

## FAILURE TO PAY OUTSTANDING FEES MAY RESULT IN THE DENIAL OF APPLICATION OR REFUSAL TO CONTINUE PROCESSING

SEQRA Status: \_\_DISCUSSION OF ITEMS NEEDED TO START PROJECT AGAIN\_\_\_\_\_

## Remarks:

- In 2013 Planning Board agreed on the intersections that are to be studied for the traffic study
- 2. Ken Wersted is going to work with Gordon Stansbury on the traffic study and see what counts can be reused and if there needs be an updated study
- 3. Mari to look at the Part 2 and see what needs to be updated.
- 4. Applicant to fill out new EAF because the forms have changed
- 5. The sewer is proposed to go through the adjacent lot, then down through the trailer park out to the Town road for municipal sewer.
- 6. Discussion on if the connections should be made for sewer prior to Zimmerman Road being paved. Applicant should coordinate with the Town
- 7. DPW thinks water is available for this project. They need to go to Town Board to get the water extension. 36 gpm is needed for the project
- 8. There are ground water issues that need to be addressed. Kirk and Will discussed a possible solution that should be drawn and presented.
- 9. A secondary driveway is needed on the site plan

- 10. The parking needs to be changed to follow the Town code
- 11. Need to go to ARB
- 12. Discussion of whether or not we need a concept plan for the adjacent lot prior to moving forward with this site plan. Question of segmentation and if the adjacent lot is viable for a development because of the road access.
- 13. The site plan needs to be modified to meet the current zoning
- 14. A sidewalk plan is needed. There may have been a deal with the Town if we give them water then sidewalks will be installed. This needs to be researched
- 15. Snow storage area is needed in the cul-da-sacs.